



Tender Amendment/ Clarification Document

Date: 12th June, 2023

Ref.: GIPCL/RE Park/TL

To,

Prospective Bidder(s),

Sub: Amendments/ Clarifications to "Tender Enquiry Document for 400 kV Transmission Lines of 2375 MW Solar / Wind / Hybrid RE Park at Great Rann of Kutch Area, Gujarat."

Ref.: Tender Enquiry Document No. GIPCL/RE Park/TL, dated 03rd April 2023.

- (1) GIPCL has floated the Tender Enquiry Document for 400 kV Transmission Lines of 2375 MW Solar / Wind / Hybrid RE Park at Great Rann of Kutch Area, Gujarat (GIPCL/RE Park/TL).
- (2) GIPCL received queries from various potential Bidders in response to the Tender.
- (3) Based on the deliberations with participants in the Pre-Bid Meeting, amendments/ clarifications to the Tender Enquiry Documents are being issued (The "Amendment Document").
- (4) This Amendment Document shall now be considered as an integral part of the Tender Enquiry Document. All other terms and conditions applicable to the Tender shall now be applicable to this Amendment Document also. Any amendments/clarifications indicated in this Amendment Document shall supersede all relevant terms and conditions/ clauses of the EPC Tender.
- (5) The Bidder shall understand, duly sign and seal each page of this Amendment/Clarification Document and submit as per the method / procedure mentioned in the Tender.

Yours faithfully,

For and on behalf of GIPCL

Sd/-

General Manager (RE Projects & IT)

Enclosed: 1). Attachment-1 (Amendment-1).
2). Consolidated Response to Bidder's Queries.



Attachment-1 (Amendment-1)

Date: 12.06.2023

IMPORTANT NOTE

Amendment / Addendum / Clarification / Corrigendum issued herein shall form part of Tender Enquiry Document on 03rd April 2023. All Bidders to please note that Amendment/Addendum/Clarification/Corrigendum issued will supersede the respective Clause / Sub-Clause of Original Tender Enquiry Document to the extent for the Clause / Sub-Clause or part thereof the amendment is issued. All other terms and conditions of the original Tender Enquiry Document No: GIPCL/RE Park/TL published on 03rd April 2023 will remain unchanged.



Amendment to the TED GIPCL/RE Park/TL

All the Tender Terms & Conditions will remain unchanged other than the below Amended Term

Sl.No	Volume/Section	Clause No.	Page No.	Original Term		Amended Term	
1.	Vol I Sec 1 NIT_TL_R2	TABLE A: IMPORTANT DATES- Sr. No. v	3 of 19	Online (e-tendering) Tender/Offer submission last date {This is mandatory}	13 th June, 2023 Time: 17:00 hours (IST) On n-procure portal for Bid Submission	Online (e-tendering) Tender/Offer submission last date {This is mandatory}	26th June, 2023 Time: 17:00 hours (IST) On n-procure portal for Bid Submission
2.	Vol I Sec 1 NIT_TL_R2	TABLE A: IMPORTANT DATES- Sr. No. vi	3 of 19	Physical receipt of Bid with all the relevant documents last date (By RPAD or Speed Post or By Personal Messenger) {This is mandatory}	14 th June, 2023 Venue: GIPCL Corporate Office, PO: Ranoli - 391 350, Dist. Vadodara.	Physical receipt of Bid with all the relevant documents last date (By RPAD or Speed Post or By Personal Messenger) {This is mandatory}	27th June, 2023 Venue: GIPCL Corporate Office, PO: Ranoli - 391 350, Dist. Vadodara.
3.	Vol I Sec 2 ITB_TL_R2	2.2.1	5 of 11	Technical Experience: The Bidder must have executed on Turnkey basis including Supplied, Erected & Commissioned minimum 12 km (Route length) of 400 kV or above voltage class transmission lines in any financial year during the last seven years as on the date of bid submission. The WO / PO / LOA / certificate for transmission line executed which is connected to state transmission utilities / central transmission utilities / Joint Venture Company of Central utility shall be considered.		Technical Experience: The Bidder must have executed on Turnkey basis including Supplied, Erected & Commissioned minimum 12 05 km (Route length) of 400 kV or above voltage class transmission lines in any financial year during the last seven years as on the date of bid submission. The WO / PO / LOA / certificate for transmission line executed which is connected to state transmission utilities / central transmission utilities / Joint Venture Company of Central utility shall be considered.	
4.	Vol I Sec 2 ITB_TL_R2	2.3 (i)	5 of 11	FINANCIAL (i) Minimum Average Annual Turnover (MAAT) of the Bidder for last three (3) financial years shall be at least Rs. 35 Crores		FINANCIAL (i) Minimum Average Annual Turnover (MAAT) of the Bidder for last three (3) financial years out of past seven (7) years shall be at least Rs. 35 30 Crores	
5.	Vol II SEC-1-GTS_TL	1.1.0 (i)	3 of 33	400 kV Single Circuit Transmission Line between PSS-1 to CTUIL KPS-II S/s on double circuit towers with last 500 meters (approximately) on multi circuit tower(s) (four circuit towers to be shared with other developer).		400 kV Single Circuit Transmission Line between PSS-1 to CTUIL KPS-II S/s on double circuit towers with last 500 meters (approximately) on multi circuit tower(s) (four circuit towers to be shared with other developer). If any one or more circuit of Multi Circuit towers are not installed, then bidder has to take care of the design aspects of unbalanced loading and reaction forces of the transmission system during the detail engineering.	



Sl.No	Volume/Section	Clause No.	Page No.	Original Term	Amended Term
6.	Vol II SEC-1-GTS_TL	12.2.0	17 of 33	To Be Submitted After Award of Contract: Link Budget Calculation as per CEA regulations	To Be Submitted After Award of Contract: Link Budget Calculation as per CEA regulations
7.	Vol II SEC-2.2-DTS_Towers and Accessories	2.2.0	4 of 18	For this package, the towers shall be designed for Wind Zone – IV (47m/s), Seismic Zone- V and Corrosion Zone C5-M (as per ISO 12944).	For this package, the towers shall be designed for Wind Zone – IV (47m/s) with Coastal factor (K4=1.3) , Seismic Zone- V and Corrosion Zone C5-M (as per ISO 12944).
8.	Vol II SEC-2.7 DTS_Tower Foundation	16.0.0	13 of 14	PERMITTED EXTRA CONSUMPTION OF LINE MATERIALS -	Clause 16.0.0 (In complete) Not Applicable / Deleted.